





RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District:Haveri

Sub Division: Ranebennur laboratory

TEST REPORT					
Location : JAIN PUBLIC SCHOOL CHALAGERI Tq :Ranebennur				Report date: 21/01/2026	
				Reference : Sample Receipt Form	
				Sample code: RAN26JAN0142	
				Date of Sample collection: 20/01/2026	
				Analysis start date: 20/01/2026	
				Analysis completion date: 21/01/2026	
Sample Particulars: FILTER (Drinking Water)				Sample collection protocol: APHA Method	
				Sample quantity:1000ml	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colour less Sample					
1	pH @25.6 °C	7.56	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance,µS/cm@ 25.9°C	366	-	-	IS 3025 (Part-14) : 2013
3	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) : 2021
4	Turbidity, NTU	0.05	1	5	IS 3025 (Part-10) : 2023
5	Total Dissolved Solids@ 179°C, mg/l	220	500	2000	IS 3025 (Part-16) : 2023
6	Alkalinity as CaCO ₃ , mg/l	39.80	200	600	IS 3025 (Part-23) : 2023
7	Total Hardness as CaCO ₃ , mg/l	40.44	200	600	IS 3025 (Part-21) : 2009
8	Calcium as Ca, mg/l	8.09	75	200	IS 3025 (Part-40) : 2024
9	Magnesium as Mg, mg/l	4.91	30	100	IS 3025 (Part-46) : 2023
10	Chloride as Cl, mg/l	34.71	250	1000	IS 3025 (Part-32) : 1988
11	Sulphate as SO ₄ , mg/l	7.58	200	400	IS 3025 (Part-24) : 2022
12	Fluoride as F, mg/l	0.367	1	1.5	APHA 24 th Edition
13	Nitrate as NO ₃ , mg/l	3.43	45	No relaxation	APHA 24 th Edition
14	Iron as Fe, mg/l	0.095	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample Conforms to the Acceptable/Permissible Limit of IS 10500 : 2012 RA:2018 Drinking Water Specification for The above tested parameter only. The Water Sample is Safe to Drink					
Analysed by:  Analyst : Hemamalini Hosamani			Verified by: Assistant Executive Engineer  ಸಹಾಯಕ ನಿರೀಕ್ಷಕರು ಮತ್ತು ಇಂಜಿನಿಯರರು ಗ್ರಾ.ಕು.ನಿ.ಸಂ. ಉಪ-ವಿಭಾಗ ರಾಣಬೆನ್ನೂರು		

Note:



- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District:Haveri

Sub Division: Ranebennur laboratory

TEST REPORT					
Location : JAIN PUBLIC SCHOOL CHALAGERI Tq :Ranebennur				Report date: 21/01/2026	
				Reference : Sample Receipt Form	
				Sample code: RAN26JAN0141	
				Date of Sample collection: 20/01/2026	
				Analysis start date: 20/01/2026	
				Analysis completion date: 21/01/2026	
Sample collection protocol: APHA Method				Sample quantity:1000ml	
Sample Particulars: BOREWELL					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colour less Sample					
1	pH @25.6 °C	7.17	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance,µS/cm@ 25.9°C	1450	-	-	IS 3025 (Part-14) : 2013
3	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) : 2021
4	Turbidity, NTU	0.05	1	5	IS 3025 (Part-10) : 2023
5	Total Dissolved Solids@ 179°C, mg/l	870	500	2000	IS 3025 (Part-16) : 2023
6	Alkalinity as CaCO ₃ , mg/l	557.2	200	600	IS 3025 (Part-23) : 2023
7	Total Hardness as CaCO ₃ , mg/l	525.67	200	600	IS 3025 (Part-21) : 2009
8	Calcium as Ca, mg/l	97.13	75	200	IS 3025 (Part-40) : 2024
9	Magnesium as Mg, mg/l	68.72	30	100	IS 3025 (Part-46) : 2023
10	Chloride as Cl, mg/l	163.92	250	1000	IS 3025 (Part-32) : 1988
11	Sulphate as SO ₄ , mg/l	89.17	200	400	IS 3025 (Part-24) : 2022
12	Fluoride as F, mg/l	0.879	1	1.5	APHA 24 th Edition
13	Nitrate as NO ₃ , mg/l	22.13	45	No relaxation	APHA 24 th Edition
14	Iron as Fe, mg/l	0.194	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample Conforms to the Acceptable/Permissible Limit of IS 10500 : 2012 RA:2018 Drinking Water Specification for The above tested parameter only. The Water Sample Safe to Drink					
Analysed by:  Analyst : Hemamalini Hosamani			Verified by: Assistant Executive Engineer  ಇ.ಕು.ನಿ. - ರಾಜೀವ್ ನ್ನೂರು		

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Remitter's copy



Challan Validity ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ	District ಜಿಲ್ಲೆ	Department Name ಇಲಾಖಾ ಹೆಸರು	DDO Office ಡಿಡಿಓ ಕಛೇರಿ	
Challan expires On 28/01/2026	HAVERI	RURAL DRINKING WATER & SANITATION DEPARTMENT	RURAL DRINKING WATER SANITATION DIVISION, HAVERI	
Category ವರ್ಗ	Date ದಿನಾಂಕ	Challan Reference Number ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ	DDO Code ಡಿಡಿಓ ಕೋಡ್	
Government	22/1/2026	CR0126021500289649	335820	
Remitter Name ಸಂದಾಯದಾರನ ಹೆಸರು	ASSISTANT EXECUTIVE ENGINEER RURAL DRINKING WATER SANITATION DIVISION HAVERI SUB DIVISION RANEBENNUR		Mobile Number ಮೊಬೈಲ್ ಸಂಖ್ಯೆ	8618347751
Address ವಿಳಾಸ	RANEBENNUR		E-Mail ಇ-ಮೇಲ್	rdwsd.wqmsp.ranebennurlab@gmail.com
Purpose ಉದ್ದೇಶ	Head of Account ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ	Sub Purpose Name ಉಪ ಉದ್ದೇಶ ಹೆಸರು	Purpose Specific ID ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ	Amount ಮೊತ್ತ
WATER QUALITY TESTING FEE UNDER JAL JEEVAN MISSION	0215~01~501~0~01~000	NA	NA	773
		Grand Total ಒಟ್ಟು ಮೊತ್ತ		773.00
Remittance Bank ಸಂದಾಯ ಮಾಡುವ ಬ್ಯಾಂಕ್	STATE BANK OF INDIA	Total Amount in Words ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ		Seven Hundred Seventy Three
Payment Status ಪಾವತಿ ಹಂತ	Payment Yet To Be Made At Agency Bank			
Payment Details ಪಾವತಿ ವಿವರಗಳು				
Payment Mode ಪಾವತಿ ವಿಧ	Cash			

ಇಲಾಖಾ
ಸ್ವೀಕೃತಿ
ಹಿರಿಯ ಅಧಿಕಾರಿ
ರೂರಲ್ ಡ್ರಿಂಕಿಂಗ್ ವಾಟರ್ ಸಾನಿಟೇಷನ್
ಡಿವಿಷನ್, ಹಾವೇರಿ